

## N O T I C E

THIS DOCUMENT HAS BEEN REPRODUCED FROM  
MICROFICHE. ALTHOUGH IT IS RECOGNIZED THAT  
CERTAIN PORTIONS ARE ILLEGIBLE, IT IS BEING RELEASED  
IN THE INTEREST OF MAKING AVAILABLE AS MUCH  
INFORMATION AS POSSIBLE

34901-H003-R0-00

NASA CR-

160770

---

# ADVANCED FLIGHT DESIGN SYSTEMS SUBSYSTEM PERFORMANCE MODELS

---

JUNE 1980

CONTRACT NO. NAS9-15793

## SAMPLE MODEL ENVIRONMENTAL ANALYSIS ROUTINE LIBRARY

(NASA-CR-160770) ADVANCED FLIGHT DESIGN  
SYSTEMS SUBSYSTEM PERFORMANCE MODELS.

N80-31046

SAMPLE MODEL: ENVIRONMENTAL ANALYSIS

ROUTINE LIBRARY (TRW Defense and Space

Unclas

Systems Group) 40 p HC A03/MF A01 CSCL 06K G3/54

28523

Prepared By

K. C. Parker

J. G. Torian

Systems Engineering and Analysis

Department

**TRW**

DEFENSE AND SPACE SYSTEMS GROUP



---

# **ADVANCED FLIGHT DESIGN SYSTEMS SUBSYSTEM PERFORMANCE MODELS**

---

**JUNE 1980**

**CONTRACT NO. NAS9-15793**

## **SAMPLE MODEL ENVIRONMENTAL ANALYSIS ROUTINE LIBRARY**

**Prepared By**

**K. C. Parker**

**J. G. Torian**

**Systems Engineering and Analysis**

**Department**

**TRW**

**DEFENSE AND SPACE SYSTEMS GROUP**

## PREFACE

Subsystem performance analysis is required in Flight Design to assess the capability of the Environmental Control and Life Support System (ECLSS) to support the flight requirements and define operational procedures under contingency flight conditions. Current ECLSS modeling techniques are limited in the variety of configurations and they employ batch mode computer program execution methods. Future spacecraft will require analysis of both a greater variety and a greater number of ECLSS than for previous spacecraft programs. Improvements in the variety of configurations that can be modeled and a reduction in effort required for modeling and analysis can be accomplished by developing a modular computer library program which operates interactively.

An effort has been conducted to develop a modular interactive ECLSS performance analysis tool. The final reports on the effort are included in an Executive Summary and two Technical Reports. The Technical Reports include a User Guide and a sample model.

The Executive Summary presents an overview of the effort.

The Technical Reports include a User Guide which, due to the modular nature of the Program Library, includes a greater degree of technical detail than one for a conventional program. This Sample Model report supplements the User Guide and illustrates a complete ECLSS model set up and execution.

## CONTENTS

	Page
1. Introduction . . . . .	1.1
2. Sample ECLSS Model Description . . . . .	2.1
3. Sample ECLSS Model Execution and Output . . . . .	3.1
Appendix A Computer Control Information . . . . .	3.26

## LIST OF FIGURES

	Page
2.1 Sample Model Schematic . . . . .	2.2
3.1 Program Initialization and Control . . . . .	3.4
3.2 Utility Input and Component Data . . . . .	3.5
3.3 Boundary Condition and Print Control . . . . .	3.15
3.4 Performance Data Output . . . . .	3.17
3.5 Plot Data Output . . . . .	3.23
A-1 Map . . . . .	3.27
A-2 Computer Control . . . . .	3.28

## LIST OF TABLES

	Page
3.1 Sample Model Driver (MAIN) . . . . .	3.2

## 1. INTRODUCTION

This report presents a sample Environmental Control and Life Support (ECLSS) model performance analysis using the Environmental Analysis Routines Library (EARL). This volume supplements the user's Guide to provide an example of a complete model set up and execution. The particular model was synthesized to utilize all of the component performance routines and most of the program options. The subsequent text presents a description of the synthesized ECLSS, the driver Routine (MAIN), and the various displays in the order they appear in execution. The MAP and Computer Control Statements are given in Appendix A.



## 2. SAMPLE ECLSS MODEL DESCRIPTION

A schematic of the ECLSS to be analyzed is given on Figure 2.1\*. The system consists of an atmospheric loop and a payload loop interfaced to a liquid heat rejection loop.

The atmospheric coolant enters the cabin at Node 1 and exits into a CO<sub>2</sub> removal system at Node 2. Cabin make-up Nitrogen and Oxygen are extracted from Source 1 and 2. CO<sub>2</sub> removal canisters are provided from Source 3. Moisture removal is accomplished between Nodes 3 and 4. The moisture removal system rejects heat to the liquid loop at Nodes 7 and 8 and stores the condensate in Source 4. Cabin temperature is modulated by a heater at Node 4 which controls to a prescribed temperature at the cabin outlet (Node 2). Heater power is extracted from Source 5.

The liquid heat rejection loop mixes the radiator panel outlet and radiator by-pass flow (Nodes 16, 20, and 11) into Node 5 which is a final cooling stage evaporator. The evaporator extracts its expendable media from Source 6. The liquid cools cold plated equipment between Node 6 and 7 prior to interfacing with Nodes 3 and 4 of the atmospheric coolant loop condenser. The liquid then cools a second cold plate prior to interfacing with Nodes 21 and 22 of a payload coolant loop. Radiator panel and by-pass flow are then modulated at Node 10 to control the temperature at Node 5. Node 11 is the by-pass leg. The radiator consists of two parallel sets of three panels each.

The payload loop rejects heat at Node 21 to the liquid loop (Nodes 9 and 10) for cooling of payload equipment at Node 22.

---

\* Figure 2.1 is a program produced schematic prepared from a previous run of the sample model given in this text. It does not appear in the order with respect to other displays had it been part of the sample execution.




Figure 2.1. Sample Model Schematic




Figure 2.1. Sample Model Schematic (Cont.)




Figure 2.1. Sample Model Schematic (Cont.)




Figure 2.1. Sample Model Schematic (Concl.)

### 3. SAMPLE ECLSS MODEL EXECUTION

The driver routine (MAIN 20)\* for the ECLSS described in the previous section is shown on Table 3.1.

Program Control displays are shown on Figure 3.1 In these, and subsequent displays, only the completed display is illustrated. Utility input and component data displays are shown on Figure 3.2. The Boundary Condition and Print Control information shown on Figure 3.3. These three Figures are part of the active execution. Printed performance and Plot data as output are shown on Figures 3.4 and 3.5 respectively. These latter two Figures are generated as part of the passive execution.

\* This model was executed using the MAP given in Appendix A. Several problems related to loss of Common Data have occurred executing with this particular MAP structure. These problems can be avoided by including those common blocks shown for MAIN 20 in all model driver routines.

```

2) 1: COMMON/MEAT/ K,L,TEMP,P(100,2),F(100,2),C(100,20),IC(100,1
2: COMMON/TIMES/DELT,DELTO2,TIME,TSTOP,PRNT
3: COMMON/WRITE/ IWRITE,IPRNT,ICMT,IRUN,IFRST
4: COMMON/PSST/ NPLTS,IPLT(25),JPLT(25),METFO(25)
5: COMMON/TABS/ X(500),Y(500),INTAB(20),INO
6: COMMON/LUMP2/ ATITLE(12),BIG(25),NEE(25)
7: COMMON/NEW/ MPLPTS,NERG,MOWORE
8: COMMON/EPS/ NEPS(100),DEPS(100)
9: COMMON /FLAGS/ ISDUM,ISEL,ISCHEM,ITRAJ,IEPS,ISP,IGEN
10: COMMON /ITABLE/ IASST(100,2)
11: COMMON /SEQ/ NSEQ(100),NNODES,NSEQ(100),MNODES
12: DATA IFRST/1/
13:C          INITIALIZATION
14: CALL START
15:C          UPDATE HEAT LOADS
16: 1 CONTINUE
17: C(1,4)= 2001.
18: CALL TABLE(1,TIME,C(8,4))
19: CALL STEP(2,TIME,C(22,4))
20:C          START TIMING LOOP
21:C          ATMOSPHERIC SYSTEM
22: 100 CONTINUE
23: CALL LOOP(1)
24: CALL ATNO(1,2)
25: CALL LION(2,3)
26: CALL COMWG(3,4,7,8)
27: CALL HEATER(4,1)
28: CALL COMVRG(1,5.,20,101,100)
29: 101 CONTINUE
30:C          LIQUID COOLANT SYSTEM
30:>

```

ORIGINAL PAGE IS  
OF POOR QUALITY

Table 3.1. Sample Model Driver (Main)

```

*****
FORTAN ENVIRONMENTAL
ANALYSIS ROUTINES
CONTROL DISPLAY
ENTER RUN MODE (INTEGER)
NEW START = 0
RESTART = 1
ENTER OUTPUT OPTION
NO RESTART TIME = 0
WRITE BEGINNING RESTART TAPE = 1
WRITE ENDING RESTART TAPE = 2
*****

```

```

*****
INITIALIZATION CONTROL
TFEAR
TEST PLOT OPTION
ITEM
1 COMP. TIME INCREMENT .010 HR
2 START TIME .000 HR
3 STOP TIME 5.000 HR
4 PRINT INCREMENT 1.000 HR
5 INITIAL SYSTEM TEMP 521.000 DEG
*****

```

Figure 3.1. Program Initialization and Control



```

*****
      TABLE 1
      XX      YY
      1      .000      .000
      2      .000      500.000
*****

```

```

*****
      TABLE 2
      XX      YY
      1      .000      200.000
      2      2.500      400.000
*****

```

\*\*\*\*\*

MODE 1  
ATMOSPHERIC COMPARTMENT

ITEM		VALUE	UNIT
1	COMPARTMENT VOLUME	1000.000	CUBIC FT
2	LEAKAGE RATE	2.000	LB/HR
3	COOLANT FLOW RATE	501.000	BTU/HR DEG
4	HEAT LOAD	2001.000	BTU/HR
5	SPECIFIC HEAT OF GAS	.210	BTU/LB DEG
6	PARTIAL PRESSURE OF WATER	.130	PSI
7	PARTIAL PRESSURE OF NITROGEN	11.600	PSI
8	PARTIAL PRESSURE OF OXYGEN	3.100	PSI
9	PARTIAL PRESSURE OF CARBON DIOXIDE	.093	PSI
10	TOTAL PRESSURE	14.700	PSI
11	NITROGEN TANK	1	INTEGER
12	OXYGEN TANK	2	INTEGER
13	INLET GAS TEMPERATURE	505.100	DEG

\*\*\*\*\*

\*\*\*\*\*

CREW MEMBER  
METABOLIC RATES

MODE NO. 1

ITEM	METABOLIC RATE	UNIT
1	.000	BTU/HR
2	.000	BTU/HR
3	.000	BTU/HR
4	600.000	BTU/HR
5	.000	BTU/HR
6	.000	BTU/HR

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data

\*\*\*\*\*

MODE NO. 2

LITHIUM HYDROXIDE

CANISTER

ITEM		VALUE	UNITS
1	CANISTER MASS	1.000	LBS
2	GAS FLOW RATE	501.000	BTU/HR DEG
3	CANISTER PRESSURE CHANGE	.150	PSI
4	SPECIFIC HEAT OF GAS	.210	BTU/LB DEG
5	PARTIAL PRESSURE OF WATER	.130	PSI
6	PARTIAL PRESSURE OF NITROGEN	11.600	PSI
7	OXYGEN	3.100	PSI
8	CARBON	.093	PSI
	DIOXIDE		
9	TOTAL PRESSURE	14.700	PSI
10	INITIAL ABSORBED QUANTITY	.000	FRACTION
11	CANISTER SOURCE	3	INTEGER
12	INLET GAS TEMPERATURE	510.165	DEG

\*\*\*\*\*

\*\*\*\*\*

MODE NO. 3

CONDENSING HEAT EXCHANGER  
ATMOSPHERIC SIDE

ITEM		VALUE	UNIT
	*** CALLING SIDE ***		
1	CONDENSING HEAT TRANSFER COEF.	2000.000	BTU/HR DEG
2	DRY HEAT TRANSFER COEF.	1000.000	BTU/HR DEG
3	COOLANT FLOW RATE	501.000	BTU/HR DEG
4	FLUID INLET TEMP	512.278	DEG
5	CONDENSATE TANK NO.	4	INTEGER
	*** INTERFACE SIDE ***		
6	COOLANT FLOW RATE	1490.484	BTU/HR DEG
7	FLUID INLET TEMP	499.000	DEG
	CALLING SIDE MODES	IN 3	OUT 4
	INTERFACE SIDE MODES	IN 7	OUT 8

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data (Cont.)

```

*****
                        ATMOSPHERIC COOLANT
                        PROPERTIES FOR
                        NODE NUMBER 3
                        INFORMATION ONLY
                        NOT EDITABLE
PARTIAL PRESSURE OF WATER      .133      PSIA
PARTIAL PRESSURE OF NITROGEN   11.600    PSIA
PARTIAL PRESSURE OF OXYGEN     3.100    PSIA
PARTIAL PRESSURE OF CARBON     .090    PSIA
DIOXIDE
ATMOSPHERIC PRESSURE           14.700    PSIA
*****

*****
                        NODE NUMBER 4
                        HEATER

ITEM                           VALUE      UNIT
1   THERMAL CAPACITY           200.000  BTU/DEG
2   OVERALL HEAT TRANSFER COEF. 1500.000 BTU/HR DEG
3   COOLANT FLOW RATE           501.000  BTU/HR DEG
4   INITIAL COMPONENT TEMPERATURE 521.000  DEG.
5   INITIAL INLET TEMPERATURE   500.830  DEG.
6   HEATER POWER                450.000  BTU/HR DEG.
7   CONTROL NODE NUMBER         2          INTEGER
8   CONTROL TEMPERATURE         532.000  DEG.
9   DEAD BAND                    2.000    DEG.
10  INITIAL TEMP AT CONTROL NODE 510.165  DEG
11  ATMOSPHERIC COOLANT         1          INTEGER
      0 = NO
      1 = YES
12  THERMAL COUPLING            0          INTEGER
      0 = NO
      1 = YES
13  POWER SOURCE                 5          INTEGER
      INLET NODE NO.            4
      OUTLET NODE NO.           1

*****

*****
                        ATMOSPHERIC COOLANT
                        PROPERTIES FOR
                        NODE NUMBER 4
                        INFORMATION ONLY
                        NOT EDITABLE
PARTIAL PRESSURE OF WATER      .126      PSIA
PARTIAL PRESSURE OF NITROGEN   11.600    PSIA
PARTIAL PRESSURE OF OXYGEN     3.100    PSIA
PARTIAL PRESSURE OF CARBON     .090    PSIA
DIOXIDE
ATMOSPHERIC PRESSURE           14.700    PSIA
*****

```

Figure 3.2. Utility Input and Component Data (Cont.)

\*\*\*\*\*

NODE NUMBER 5  
-EVAPORATOR

ITEM		VALUE	UNIT
1	HEAT OF VAPORAZATION	1060.000	BTU/LB
2	OVERALL HEAT TRANSFER COEF.	3000.000	BTU/HR DEG
3	COOLANT FLOW RATE	1490.484	BTU/HR DEG
4	SATURATION TEMP	495.000	DEG
5	INITAL FLUID INLET TEMP	521.000	DEG
6	CONSUMABLE	1	INTEGER .LE. 10
	1 = POTABLE WATER		
	2 = WATER		
	3 = AMMONIA		
	4 = OTHER		
7	TANK ASSIGNMENT	6	INTEGER .LE. 20
	INLET NODE NUMBER	5	
	OUTLET NODE NUMBER	6	

\*\*\*\*\*

\*\*\*\*\*

NODE NUMBER 6  
COLD PLATE

ITEM		VALUE	UNIT
1	THERMAL CAPACITY	150.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	2500.000	BTU/HR DEG
3	COOLANT FLOW RATE	1490.484	BTU/HR DEG
4	INITIAL COMPONENT TEMP.	500.000	DEG
5	INITIAL COOLANT INLET TEMP.	498.474	DEG
6	ATMOSPHERIC COOLANT	0	INTEGER
	0 = NO		
	1 = YES		
7	EPS DATA ASSIGNMENT	0	INTEGER
	0 = NO		
	1 = YES		
8	THERMAL COUPLING	0	INTEGER
	0 = NO		
	1 = YES		
	INLET NODE NUMBER	6	
	OUTLET NODE NUMBER	7	

\*\*\*\*\*

\*\*\*\*\*

NODE NO. 7  
CONDENSING HEAT EXCHANGER  
INTERFACE SIDE

ITEM		VALUE	UNIT
*** CALLING SIDE ***			
1	COOLANT FLOW RATE	1490.404	BTU/HR DEG
2	FLUID INLET TEMP.	499.715	DEG
3	ATMOSPHERIC COOLANT	0	INTEGER
	NO = 0		
	YES = 1		
*** ATMOSPHERIC SIDE ***			
4	COOLANT FLOW RATE	501.000	BTU/HR DEG
5	FLUID INLET TEMP	512.278	DEG
	CALLING SIDE NODES	IN 7 OUT 8	
	ATMOSPHERIC SIDE NODES	IN 3 OUT 4	

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data (Cont.)

\*\*\*\*\*

NODE NUMBER 8  
COLD PLATE

ITEM		VALUE	UNIT
1	THERMAL CAPACITY	200.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	3000.000	BTU/HR DEG
3	COOLANT FLOW RATE	1490.484	BTU/HR DEG
4	INITIAL COMPONENT TEMP.	521.000	DEG
5	INITIAL COOLANT INLET TEMP.	504.167	DEG
6	ATMOSPHERIC COOLANT	0	INTEGER
	0 = NO 1 = YES		
7	EPS DATA ASSIGNMENT	0	INTEGER
	0 = NO 1 = YES		
8	THERMAL COUPLING	1	INTEGER
	0 = NO 1 = YES		
	INLET NODE NUMBER	8	
	OUTLET NODE NUMBER	9	

\*\*\*\*\*

\*\*\*\*\*

THERMAL COUPLING DATA  
FOR NODE NO. 8  
COUPLED TO 1 NODES  
TYPE OF HEAT TRANSFER AND  
ITEM COUPLING NODE NUMBER CODE VALUE  
1 122 .500  
VALUES ARE:  
BTU/HR FOR SERIES 100 COUPLING  
BTU/HR DEG\*\*4 FOR SERIES 200 COUPLING  
\*\*\*\*\*

\*\*\*\*\*

NODE NO. 9

HEAT EXCHANGER

ITEM		VALUE	UNIT
*** CALLING SIDE ***			
1	HEAT TRANSFER COEF.	3000.000	BTU/HR DEG
2	COOLANT FLOW RATE	1490.484	BTU/HR DEG
3	FLUID INLET TEMPERATURE	519.751	DEG
4	TYPE	0	INTEGER
	COUNTERFLOW = 0 PARALLEL FLOW = 1		
5	ATMOSPHERIC COOLANT	0	INTEGER
	NO = 0 YES = 1		
*** INTERFACE SIDE ***			
6	HEAT TRANSFER COEF.	300.000	BTU/HR DEG
7	COOLANT FLOW RATE	100.000	BTU/HR DEG
8	FLUID INLET TEMPERATURE	521.000	DEG

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data (Cont.)

```

*****
                        NODE NUMBER 10
                        MODULATION VALUE
ITEM  DESCRIPTION                               VALUE    UNIT
1*   LEG 1 NODE NUMBER                          12    INTEGER
2*   LEG 2 NODE NUMBER                          11    INTEGER
3*   CONTROL NODE NUMBER                         5    INTEGER
4    CONTROL TEMP                               505.000  DEG
5    INITIAL TEMP AT CONTROL NODE                521.000  DEG
6    PROPORTIONAL GAINS                          .001  FRACTION/DEG
7    MAX HARD OVER                              1.000  FRACTION
8    MIN HARD OVER                              .000  FRACTION
9    INITIAL TEMP AT MOD NODE                    518.891  DEG
10   COOLANT FLOW AT MOD NODE                    1490.484 BTU/HR DEG.
11   ATMOSPHERIC COOLANT                         0    INTEGER
      0 = NO
      1 = YES
* MUST BE DEFINED BEFORE YOU EXIT DISPLAY
*****

```

```

*****
                        NODE NO. 12
                        BRANCH
                        SPLIT INTO 2 LEGS
                        LEG NODE FLOW
ITEM  NUMBER  PROPORTION
1     13      .500
2     17      .500
3   ATMOSPHERIC COOLANT 0 INTEGER
      0 = NO
      1 = YES
4   COOLANT FLOW RATE  769.090 BTU/HR DEG
5   COOLANT INLET TEMP 518.891 DEG
*****

```

```

*****
                        NODE NUMBER 13
                        RADIATOR PANEL
ITEM  VALUE    UNIT
1    THERMAL CAPACITANCE 25.000 BTU/DEG
2    OVERALL HEAT TRANSFER COEF. 1500.000 BTU/HR DEG
3    COOLANT FLOW RATE 384.545 BTU/HR DEG
4    SOLAR ABSORBIVITY .100 FRACTION
5    EMISSIVITY .900 FRACTION
6    RIGHT FIN EFFECTIVENESS .800 FRACTION
7    LEFT FIN EFFECTIVENESS .800 FRACTION
8    RIGHT FIN AREA 10.000 SQ FT
9    LEFT FIN AREA 10.000 SQ FT
10   ANGLE OF INCIDENCE .000 RAD
11   DIHEDRAL ANGLE .000 RAD
12   INITIAL FIN TEMP 521.000 DEG
13   INITIAL COOLANT INLET TEMP. 518.891 DEG
14   NODE COUPLING 0 INTEGER
      NO = 0
      YES = 1
15   SHADOW NODE NUMBER 25 INTEGER
      INLET NODE NUMBER 13
      OUTLET NODE NUMBER 14
*****

```

ORIGINAL PAGE IS  
OF POOR QUALITY

Figure 3.2. Utility Input and Component Data (Cont.)

\*\*\*\*\*

SHADOWING DATA  
FOR NODE NO. 13  
SHADOWED BY 25

ITEM		VALUE	UNIT
1	SHADOW NODE AREA	1.000	SQ FT
2	ANGLE OF INCIDENCE	.000	RAD
3	DIHEDRAL ANGLE	.000	RAD
4	STAND-OFF VECTOR DATA	26	INTEGER
5	STAND-OFF DISTANCE	2.000	FT
6	EQUIV. STAND-OFF ANGLE OF INCIDENCE	.000	RAD
7	EQUIV. STAND-OFF DIHEDRAL ANGLE	.000	RAD

\*\*\*\*\*

\*\*\*\*\*

NODE NUMBER 14  
RADIATOR PANEL

ITEM		VALUE	UNIT
1	THERMAL CAPACITANCE	25.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	1500.000	BTU/HR DEG
3	COOLANT FLOW RATE	384.545	BTU/HR DEG
4	SOLAR ABSORBIVITY	.100	FRACTION
5	EMISSIVITY	.900	FRACTION
6	RIGHT FIN EFFECTIVENESS	.800	FRACTION
7	LEFT FIN EFFECTIVENESS	.800	FRACTION
8	RIGHT FIN AREA	10.000	SQ FT
9	LEFT FIN AREA	10.000	SQ FT
10	ANGLE OF INCIDENCE	.000	RAD
11	DIHEDRAL ANGLE	.000	RAD
12	INITIAL FIN TEMP	521.000	DEG
13	INITIAL COOLANT INLET TEMP.	520.957	DEG
14	NODE COUPLING	0	INTEGER
	NO = 0 YES = 1		
15	SHADOW NODE NUMBER	0	INTEGER
	INLET NODE NUMBER      OUTLET NODE NUMBER	14      15	

\*\*\*\*\*

\*\*\*\*\*

NODE NUMBER 15  
RADIATOR PANEL

ITEM		VALUE	UNIT
1	THERMAL CAPACITANCE	25.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	1500.000	BTU/HR DEG
3	COOLANT FLOW RATE	384.545	BTU/HR DEG
4	SOLAR ABSORBIVITY	.100	FRACTION
5	EMISSIVITY	.900	FRACTION
6	RIGHT FIN EFFECTIVENESS	.800	FRACTION
7	LEFT FIN EFFECTIVENESS	.800	FRACTION
8	RIGHT FIN AREA	10.000	SQ FT
9	LEFT FIN AREA	10.000	SQ FT
10	ANGLE OF INCIDENCE	.000	RAD
11	DIHEDRAL ANGLE	.000	RAD
12	INITIAL FIN TEMP	521.000	DEG
13	INITIAL COOLANT INLET TEMP.	520.999	DEG
14	NODE COUPLING	0	INTEGER
	NO = 0 YES = 1		
15	SHADOW NODE NUMBER	0	INTEGER
	INLET NODE NUMBER      OUTLET NODE NUMBER	15      16	

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data (Cont.)

\*\*\*\*\*  
 NODE NUMBER 17  
 RADIATOR PANEL

ITEM		VALUE	UNIT
1	THERMAL CAPACITANCE	25.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	1500.000	BTU/HR DEG
3	COOLANT FLOW RATE	384.545	BTU/HR DEG
4	SOLAR ABSORBIVITY	.100	FRACTION
5	EMMISSIVITY	.900	FRACTION
6	RIGHT FIN EFFECTIVENESS	.800	FRACTION
7	LEFT FIN EFFECTIVENESS	.800	FRACTION
8	RIGHT FIN AREA	10.000	SQ FT
9	LEFT FIN AREA	10.000	SQ FT
10	ANGLE OF INCIDENCE	.000	RAD
11	DIHEDERIAL ANGLE	.000	RAD
12	INITIAL FIN TEMP	521.000	DEG
13	INITIAL COOLANT INLET TEMP.	518.891	DEG
14	NODE COUPLING	0	INTEGER

NO = 0  
 YES = 1

15 SHADOW NODE NUMBER 0 INTEGER  
 INLET NODE NUMBER 17 OUTLET NODE NUMBER 18

\*\*\*\*\*

\*\*\*\*\*  
 NODE NUMBER 18  
 RADIATOR PANEL

ITEM		VALUE	UNIT
1	THERMAL CAPACITANCE	25.000	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	1500.000	BTU/HR DEG
3	COOLANT FLOW RATE	384.545	BTU/HR DEG
4	SOLAR ABSORBIVITY	.100	FRACTION
5	EMMISSIVITY	.900	FRACTION
6	RIGHT FIN EFFECTIVENESS	.800	FRACTION
7	LEFT FIN EFFECTIVENESS	.800	FRACTION
8	RIGHT FIN AREA	10.000	SQ FT
9	LEFT FIN AREA	10.000	SQ FT
10	ANGLE OF INCIDENCE	.000	RAD
11	DIHEDERIAL ANGLE	.000	RAD
12	INITIAL FIN TEMP	521.000	DEG
13	INITIAL COOLANT INLET TEMP.	520.957	DEG
14	NODE COUPLING	0	INTEGER

NO = 0  
 YES = 1

15 SHADOW NODE NUMBER 0 INTEGER  
 INLET NODE NUMBER 18 OUTLET NODE NUMBER 19

\*\*\*\*\*

ORIGINAL PAGE IS  
 OF POOR QUALITY

Figure 3.2. Utility Input and Component Data (Cont.)



\*\*\*\*\*

NODE NUMBER 19  
RADIATOR PANEL

ITEM		VALUE	UNIT
1	THERMAL CAPACITANCE	.250	BTU/DEG
2	OVERALL HEAT TRANSFER COEF.	1500.000	BTU/HR DEG
3	COOLANT FLOW RATE	384.545	BTU/HR DEG
4	SOLAR ABSORBIVITY	.100	FRACTION
5	EMMISSIVITY	.900	FRACTION
6	RIGHT FIN EFFECTIVENESS	.800	FRACTION
7	LEFT FIN EFFECTIVENESS	.800	FRACTION
8	RIGHT FIN AREA	10.000	SQ FT
9	LEFT FIN AREA	10.000	SQ FT
10	ANGLE OF INCIDENCE	.000	RAD
11	DIHEDRAL ANGLE	.000	RAD
12	INITIAL FIN TEMP	521.000	DEG
13	INITIAL COOLANT INLET TEMP.	520.999	DEG
14	MODE COUPLING	0	INTEGER

NO = 0  
YES = 1

15	SHADOW NODE NUMBER	0	INTEGER
	INLET NODE NUMBER	19	
	OUTLET NODE NUMBER	20	

\*\*\*\*\*

\*\*\*\*\*

NODE NO. 5  
JUNCTION  
MIXING 3 NODES  
MIXED MODE

ITEM	NUMBER	UNIT
1	11	INTEGER
2	16	INTEGER
3	20	INTEGER
4	ATMOSPHERIC COOLANT	0 INTEGER

0 = NO  
1 = YES

\*\*\*\*\*

\*\*\*\*\*

MODE NO. 21

HEAT EXCHANGER

ITEM		VALUE	UNIT
*** CALLING SIDE ***			
1	HEAT TRANSFER COEF.	300.000	BTU/HR DEG
2	COOLANT FLOW RATE	100.000	BTU/HR DEG
3	FLUID INLET TEMPERATURE	521.000	DEG
4	TYPE	0	INTEGER
COUNTERFLOW = 0 PARALLEL FLOW = 1			
5	ATMOSPHERIC COOLANT	0	INTEGER
NO = 0 YES = 1			
*** INTERFACE SIDE ***			
6	HEAT TRANSFER COEF.	3000.000	BTU/HR DEG
7	COOLANT FLOW RATE	1490.484	BTU/HR DEG
8	FLUID INLET TEMPERATURE	518.751	DEG

\*\*\*\*\*

Figure 3.2. Utility Input and Component Data (Cont.)

```

*****
                      NODE NUMBER 22
                      GOLD PLATE
ITEM  THERMAL CAPACITY      150.000      BTU/DEG
1
2  OVERALL HEAT TRANSFER   300.000      BTU/HR DEG
   COEF.
3  COOLANT FLOW RATE       100.000      BTU/HR DEG
4  INITIAL COMPONENT
   TEMP.                   521.000      DEG
5  INITIAL COOLANT
   INLET TEMP.            518.916      DEG
6  ATMOSPHERIC COOLANT     0            INTEGER
   0 = NO
   1 = YES
7  EPS DATA ASSIGNMENT    0            INTEGER
   0 = NO
   1 = YES
8  THERMAL COUPLING        1            INTEGER
   0 = NO
   1 = YES
   INLET NODE NUMBER      22            OUTLET NODE NUMBER 21
*****

```

```

*****
THERMAL COUPLING DATA
FOR NODE NO. 22
COUPLED TO 1 NODES
TYPE OF HEAT TRANSFER AND
ITEM  COUPLING NODE NUMBER CODE  VALUE
1      100                      .500
VALUES ARE:
BTU/HR FOR SERIES 100 COUPLING
BTU/HR DEG**4 FOR SERIES 200 COUPLING
*****

```

Figure 3.2. Utility Input and Component Data (Concl.)

```

*****
CONSUMABLES
SOURCES
ITEM SOURCE NO. TYPE OF CONSUMABLE UNIT INITIAL
1 1 NITROGEN LBS 000
2 2 OXYGEN LBS 000
3 3 LITHIUM HYDROXIDE LBS 000
4 4 WATER LBS 000
5 5 ELECTRIC POWER WATT HRS 000
6 6 POTABLE WATER LBS 000
*****

```

```

*****
ORBITAL HEATING
CONTROL PARAMETERS
ITEM VALUE UNIT
1 CONTROL INDICATOR 2 INTEGER
  1 = READ TAPE
  2 = CALCULATE TRAJECTORY
2 UNIT CONVERSION FOR TAPE 1 INTEGER
  1 = EARTH RADIUS (ER.)
  2 = KILOMETERS (KM.)
*****

```

```

*****
ORBITAL PARAMETERS
ITEM VALUE UNIT
1 COMP FREQUENCY 1 INTEGER
2 ATTITUDE HOLD KEY 1 INTEGER
  1 = INERTIAL
  2 = LOCAL VERTICAL
3 SUN COORDINATE X 2.3466000+04 ER.
4 Y 0.0000000 ER.
5 Z 0.0000000 ER.
6 EULER ANGLE ABOUT Z .000 RAD.
7 Y .000 RAD.
8 X .000 RAD.
9 ORBIT SEMIMAJOR AXIS 1.029 ER.
10 ORBIT ECCENTRICITY .000 N/D
11 ORBIT INCLINATION .000 RAD.
12 RIGHT ASCENSION .000 RAD.
13 ARGUMENT OF PERIGEE .000 RAD.
14 TIME OF PERIGEE PASSAGE .000 ER.
*****

```

Figure 3.3. Boundary Condition and Print Control

ORIGINAL PAGE  
OF 2000

```

*****
PRINT OPTION
DISPLAY
ITEM  OPTION  FLAG
1     SELECT  STATUS
2     NODES   0
3     PLOTS   1
      SCHEMATIC 0
*****

```

```

*****
FUNCTION MENU
DESCRIPTION
YPE 1 FLUID TEMP (DEG/R)
2 COMP TEMP (DEG/R)
3 FLOW RATE (LBS/HR)
4 HEAT (BTU/HR)
5 ACC CONSUM (LBS)
6 HEATER PWR (BTU/HR)
7 PRT PRES H2O (PSI)
8 PRT PRES N2 (PSI)
9 PRT PRES O2 (PSI)
10 PRT PRES CO2 (MMHG)
11 HTR ENERGY (BTU)
*****

```

```

*****
PLOT CONTROL
TEM  NODE NO  TYPE  MAX  MIN
1    2    FLUID TEMP  .000  .000
2    12   FLOW RATE   .000  .000
3    22   HEAT        .000  .000
*****

```

Figure 3.3. Boundary Condition and Print Control (Concl.)

\*\*\*\*\*  
 TFEAR  
 TEST PLOT OPTION

TIME = .000

# FLUID PROPERTIES

NODE NO		COMP TEMP DEG	FLUID TEMP DEG	WCP BTU/HR DEG	HEAT LOAD BTU/HR
1	CABIN IN		519.990	501.000	2001.000
2	CABIN OUT		510.165	501.000	
3	LIOH OUT		512.278	501.000	
4	COND. OUT	521.000	500.830	501.000	450.000
5	EVAP IN	495.000	519.970	1490.484	
6	EVAP OUT	500.000	498.474	1490.484	
7	PLATE OUT		499.715	1490.484	6636.095
8	INTF OUT	521.000	504.167	1490.484	
9	PLATE OUT		518.751	1490.484	
10	EXCH OUT		518.891	1490.484	
12	LEG		518.891	769.090	
11	LEG		518.891	721.394	
13	LEG	521.000	518.891	384.545	
17	LEG	521.000	518.891	384.545	
14	RADOUT	521.000	520.957	384.545	
15	RADOUT	521.000	520.999	384.545	
16	RADOUT		521.000	384.545	
18	RADOUT	521.000	520.957	384.545	
19	RADOUT	521.000	520.999	384.545	
20	RADOUT		521.000	384.545	
21	EXCH IN		520.896	100.000	
22	EXCH OUT	521.000	518.916	100.000	200.000

\*\*\*\*\*  
 \*\*\*\*\*

# GAS PROPERTIES

TIME = .000

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.126	11.600	3.100	.090	14.700
2	.210	.130	11.600	3.100	.093	14.700
3	.210	.133	11.600	3.100	.090	14.700
4	.210	.126	11.600	3.100	.090	14.700

\*\*\*\*\*  
 PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

# \*\*\*\*\* CONSUMABLES USAGE

TIME =	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
SOURCE			
1	.000	.000	.000
2	.000	.000	.000
3	.000	.000	.000
4	.000	.000	.000
5	.000	.000	.000
6	.000	.000	.000

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output

\*\*\*\*\*

TFEAR  
TEST PLOT OPTION

FLUID PROPERTIES

TIME = 1.000

NODE NO			COMP TEMP DEG	FLUID TEMP DEG	WCP BTU/HR DEG	HEAT LOAD BTU/HR
1	CABIN IN	/HEATER OUT		500.405	501.000	2001.000
2	CABIN OUT	/LIQH IN		505.543	501.000	
3	LIQH OUT	/COND. IN		506.041	501.000	
4	COND. OUT	/HEATER IN	500.574	436.495	501.000	450.000
5	EVAP IN	/JUNCTION	495.000	496.417	1490.484	
6	EVAP OUT	/PLATE IN	495.220	495.187	1490.484	
7	PLATE OUT	/INTF IN		495.215	1490.484	4981.428
8	INTF OUT	/PLATE IN	499.234	498.557	1490.484	100.000
9	PLATE OUT	/EXCH IN		499.161	1490.484	
10	EXCH OUT	/DIVERT		500.071	1490.484	
12	LEG	/BRANCH		500.071	318.282	
11	LEG	/MIXER		500.071	1172.202	
13	LEG	/RADIN	493.701	500.071	159.141	
17	LEG	/RADIN	493.701	500.071	159.141	
14	RADOUT	/RADIN	488.900	493.798	159.141	
15	RADOUT	/RADIN	485.021	489.034	159.141	
16	RADOUT	/MIXER		485.175	159.141	
18	RADOUT	/RADIN	488.900	493.798	159.141	
19	RADOUT	/RADIN	480.461	489.034	159.141	
20	RADOUT	/MIXER		480.741	159.141	
21	EXCH IN	/PLATE OUT		513.737	100.000	
22	EXCH OUT	/PLATE IN	514.404	500.275	100.000	200.000

\*\*\*\*\*

GAS PROPERTIES

TIME = 1.000

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.106	11.600	3.100	.077	14.700
2	.210	.107	11.600	3.100	.077	14.700
3	.210	.108	11.600	3.100	.077	14.700
4	.210	.106	11.600	3.100	.077	14.700

\*\*\*\*\*

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

\*\*\*\*\*

CONSUMABLES  
USAGE

TIME = 1.000

SOURCE	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
1	.000	1.532	-1.532
2	.000	.565	-.565
3	.000	.000	.000
4	.000	.263	-.263
5	.000	131.965	-131.965
6	.000	8.498	-8.498

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output (Cont.)

\*\*\*\*\*

TPEAR  
TEST PLOT OPTION

# FLUID PROPERTIES

TIME = 2.000

NODE NO			COMP TEMP DEG	FLUID TEMP DEG	MCP BTU/HR DEG	HEAT LOAD BTU/HR
1	CABIN IN	/HEATER OUT		497.571	501.000	2001.000
2	CABIN OUT	/L7OH IN		502.644	501.000	
3	L7OH OUT	/COND. IN		503.005	501.000	
4	COND. OUT	/HEATER IN	497.632	496.320	501.000	450.000
5	EVAP IN	/JUNCTION	495.000	498.059	1490.482	
6	EVAP OUT	/PLATE IN	495.424	495.410	1490.482	
7	PLATE OUT	/INTF IN		495.421	1490.482	3497.986
8	INTF OUT	/PLATE IN	497.990	497.768	1490.482	200.000
9	PLATE OUT	/EXCH IN		497.962	1490.482	
10	EXCH OUT	/DIVERT		498.574	1490.482	
12	LEG	/BRANCH		498.574	7.452	
11	LEG	/MIXER		498.574	1483.030	
13	LEG	/RADIN	453.141	498.574	3.726	
17	LEG	/RADIN	453.141	498.574	3.726	
14	RADOUT	/RADIN	446.023	453.318	3.726	
15	RADOUT	/RADIN	442.470	446.216	3.726	
16	RADOUT	/MIXER		442.659	3.726	
18	RADOUT	/RADIN	446.023	453.318	3.726	
19	RADOUT	/RADIN	348.510	446.216	3.726	
20	RADOUT	/MIXER		348.601	3.726	
21	EXCH IN	/PLATE OUT		507.758	100.000	
22	EXCH OUT	/PLATE IN	508.209	498.691	100.000	200.000

\*\*\*\*\*

# GAS PROPERTIES

TIME = 2.000

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.105	11.600	3.100	.070	14.700
2	.210	.106	11.600	3.100	.071	14.700
3	.210	.106	11.600	3.100	.070	14.700
4	.210	.105	11.600	3.100	.070	14.700

\*\*\*\*\*  
PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

\*\*\*\*\*

# CONSUMABLES USAGE

TIME = 2.000

SOURCE	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
1	.000	3.065	-3.065
2	.000	1.131	-1.131
3	.000	.000	.000
4	.000	-383	383
5	.000	263.929	-263.929
6	.000	12.292	-12.292

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output (Cont.)



\*\*\*\*\*

TFEAR  
TEST PLOT OPTION

FLUID PROPERTIES

TIME = 3.000

NODE NO		COMP TEMP DEG	FLUID TEMP DEG	WCP BTU/HR DEG	HEAT LOAD BTU/HR
1	CACIN IN		497.165	501.000	2001.000
2	CABIN OUT		502.231	501.000	
3	LICH OUT		502.510	501.000	
4	COND. OUT	497.215	496.202	501.000	450.000
5	EVAP IN	495.000	497.580	1490.482	
6	EVAP OUT	495.350	495.345	1490.482	
7	PLATE OUT		495.349	1490.482	3305.164
8	INTF OUT		497.566	1490.482	300.000
9	PLATE OUT	497.807	497.775	1490.482	
10	EXCH OUT		498.214	1490.482	
12	LEG		498.214	7.452	
11	LEG		498.214	1483.029	
13	LEG	425.292	498.214	3.726	
17	LEG	425.292	498.214	3.726	
14	RADOUT	413.539	425.401	3.726	
15	RADOUT	410.168	413.677	3.726	
16	RADOUT		410.307	3.726	
18	RADOUT	413.540	425.401	3.726	
19	RADOUT	332.595	413.677	3.726	
20	RADOUT		332.665	3.726	
21	EXCH IN		504.822	100.000	
22	EXCH OUT	505.155	498.295	100.000	400.000

\*\*\*\*\*

GAS PROPERTIES

TIME = 3.000

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.105	11.600	3.100	.068	14.700
2	.210	.105	11.600	3.100	.069	14.700
3	.210	.106	11.600	3.100	.068	14.700
4	.210	.105	11.600	3.100	.068	14.700

\*\*\*\*\*  
PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

\*\*\*\*\*

CONSUMABLES  
USAGE

TIME = 3.000

SOURCE	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
1	.000	4.597	-4.597
2	.000	1.696	-1.696
3	.000	.000	.000
4	.000	.486	-.486
5	.000	395.894	-395.894
6	.000	15.672	-15.672

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output (Cont.)



```

*****
TEAR
TEST PLOT OPTION
FLUID PROPERTIES
TIME = 4.000

```

NODE NO			COMP TEMP DEG	FLUID TEMP DEG	WCP BTU/HR DEG	HEAT LOSS BTU/HR
1	CABIN IN	HEATER OUT		497.073	501.000	2001.000
2	CABIN OUT	LITON IN		502.138	501.000	
3	LITON OUT	COND. IN		502.363	501.000	
4	COND. OUT	HEATER IN	497.121	506.166	501.000	450.000
5	EVAP IN	THROTTL	495.000	497.000	1490.482	
6	EVAP OUT	PLATE IN	495.323	495.321	1490.482	
7	PLATE OUT	INTF IN		495.323	1490.482	3239.835
8	INTF OUT	PLATE IN	497.304	497.496	1490.482	400.000
9	PLATE OUT	EXCH IN		497.762	1490.482	
10	EXCH OUT	DIVERT		498.125	1490.482	
12	LEG	BRANCH		498.125	7.452	
11	LEG	MIXER		498.125	1453.019	
13	LEG	RADIN	407.706	498.125	3.726	.012
17	LEG	RADIN	407.706	498.125	3.726	.012
14	RADOUT	RADIN	389.867	407.776	3.726	.013
15	RADOUT	RADIN	389.774	389.970	3.726	.013
16	RADOUT	MIXER		389.981	3.726	
18	RADOUT	RADIN	389.867	407.777	3.726	.013
19	RADOUT	RADIN	389.268	389.970	3.726	.013
20	RADOUT	MIXER		389.973	3.726	
21	EXCH IN	PLATE OUT	503.063	503.506	100.000	
22	EXCH OUT	PLATE IN		498.197	100.000	400.000

```

*****
GAS PROPERTIES
TIME = 4.000

```

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.105	11.600	3.100	.069	14.700
2	.210	.105	11.600	3.100	.069	14.700
3	.210	.105	11.600	3.100	.069	14.700
4	.210	.105	11.600	3.100	.069	14.700

\*\*\*\*\*  
PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

```

*****
CONSUMABLES
USAGE
TIME = 4.000

```

SOURCE	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
1	.000	6.129	-6.129
2	.000	2.261	-2.261
3	.000	.000	.000
4	.000	.577	-.577
5	.000	527.858	-527.858
6	.000	19.693	-19.693

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output (Cont.)

\*\*\*\*\*

TFEAR  
TEST PLOT OPTION

FLUID PROPERTIES

TIME = 5.000

NODE NO			COMP TEMP DEG	FLUID TEMP DEG	WCP BTU/HR DEG	HEAT LOAD BTU/HR
1	CABIN IN	/HEATER OUT		497.041	501.000	2001.000
2	CABIN OUT	/LIQH IN		502.106	501.000	
3	LIQH OUT	/COND. IN		502.291	501.000	
4	COND. OUT	/HEATER IN	497.089	496.131	501.000	450.000
5	EVAP IN	/JUNCTION	495.000	497.314	1490.482	
6	EVAP OUT	/PLATE IN	495.310	495.309	1490.482	
7	PLATE OUT	/INTF IN		495.310	1490.482	3203.921
8	INTF OUT	/PLATE IN	497.844	497.460	1490.482	500.000
9	PLATE OUT	/EXCH IN		497.793	1490.482	
10	EXCH OUT	/DIVERT		498.111	1490.482	
12	LEG	/BRANCH		498.111	7.452	
11	LEG	/MIXER		498.111	1483.029	
13	LEG	/RADIN	396.171	498.111	3.726	
17	LEG	/RADIN	396.172	498.111	3.726	
14	RADOUT	/RADIN	372.059	396.218	3.726	
15	RADOUT	/RADIN	366.563	372.136	3.726	
16	RADOUT	/MIXER		366.649	3.726	
18	RADOUT	/RADIN	372.059	396.219	3.726	
19	RADOUT	/RADIN	310.490	372.172	3.726	
20	RADOUT	/MIXER		310.51	3.726	
21	EXCH IN	/PLATE OUT		502.911	100.000	
22	EXCH OUT	/PLATE IN	503.156	498.170	100.000	400.000

\*\*\*\*\*  
\*\*\*\*\*

GAS PROPERTIES

TIME = 5.000

NODE NO	SPECIFIC HEAT	WATER PSI	NITROGEN PSI	OXYGEN PSI	CO2 PSI	TOTAL PSI
1	.210	.104	11.600	3.100	.071	14.700
2	.210	.105	11.600	3.100	.072	14.700
3	.210	.105	11.600	3.100	.071	14.700
4	.210	.104	11.600	3.100	.071	14.700

\*\*\*\*\*  
PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

CONSUMABLES  
USAGE

TIME = 5.000

SOURCE	INITIAL AVAILABLE	QUANTITY USED	QUANTITY REMAINING
1	.000	7.661	-7.661
2	.000	2.827	-2.827
3	.000	.000	.000
4	.000	-.661	.661
5	.000	659.823	-659.823
6	.000	21.559	-21.559

PAUSE FOR HARDCOPY. ENTER ANY CHARACTER TO CONTINUE

Figure 3.4. Performance Data Output (Concl.)




Figure 3.5. Plot Data Output





Figure 3.5. Plot Data Output (Cont.)

# GENERATE PLOTS FOR CONSUMABLES ROUTINES



ORIGINAL PAGE IS  
POOR QUALITY

Figure 3.5. Plot Data Output (Concl.)

APPENDIX A  
COMPUTER CONTROL INFORMATION

# MAP USED TO EXECUTE MAIN20 PROGRAM.

```

1:SEG NAME
2:IN FM2-T61867*FEAR.MAIN20
3:SEG A*,(NAME)
4:IN FM2-T61867*FEAR.START
5:SEG B*,(NAME)
6:IN FM2-T61867*FEAR.LOOP
7:SEG C*,(NAME)
8:IN FM2-T61867*FEAR.SPLIT,FM2-T61867*FEAR.PLOTE
9:SEG D*,(NAME)
10:IN FM2-T61867*FEAR.MIN,FM2-T61867*FEAR.MOD, FM2-T61867*FEAR.EVMD
11:SEG E*,(NAME)
12:IN FM2-T61867*FEAR.CONVERG
13:SEG F*,(NAME)
14:IN FM2-T61867*FEAR.PRINT
15:SEG G*,(NAME)
16:IN FM2-T61867*FEAR.TABLE/NEW,FM2-T61867*FEAR.STEP/NEW
17:SEG F1*,(F)
18:IN FM2-T61867*FEAR.DTANK,FM2-T61867*FEAR.TRAJ,FM2-T61867*FEAR.DT
TAPE
19:SEG F2*,(F)
20:IN DPLOOT
21:SEG F3*,(F)
22:IN FM2-T61867*FEAR.SCHEN/PLAT
23:SEG F31*,(F3)
24:IN ALFACT,CARTOG
25:SEG F32*,(F3)
26:IN DATA,CATB,CATC
27:SEG F33*,(F3)
28:IN BARS
29:SEG F4*,(F)
30:IN FM2-T61867*FEAR.GASPR,FM2-T61867*FEAR.CONPR,FM2-T61867*FEAR.E
EPS/NEW
31:SEG F5*,(F)
32:IN FM2-T61867*FEAR.PLOOT
33:END 1000/0227
34:LIB FM2-T61867*FEAR.
35:LIB MOD*LOCALIB.
36:LIB DISPLA*LIB.
37:LIB F06*MODSPLT.
EOF:37 SCAN:36
0:>

```

Figure A-1. MAP

```

ENTER USERID/PASSWORD:
>
*DESTROY USERID/PASSWORD ENTRY
*UNIVAC 1100 OPERATING SYSTEM VER. 30R30#A09-G1(RSI)*
>%RHA 660KPC,FM2/9212,TBW-153091
DATE: 061780 TIME: 145306
>%ASG,A FM2-T61867*FEAR/0061.
READY
>%USE ALT.,FM2-T61867*FEAR/L/0061. PROGRAM FILE
READY
>%ASE,A DATA.
FACILITY REJECTED 400010000000
>%ASE,CP DATA.
READY
>%ISC*CALLUP.TAPES 153091*660KPC.,X11837 RESTART TAPE
REQUEST HAS BEEN ACCEPTED
>%FREE DATA.
READY
>%ASE,A DATA.
READY
>%USE 1.,DATA. FORTRAN UNIT 1
READY
>%ASE,CP PLOTS,F/400//1000 INTERMEDIATE PLOT FILE
READY
>%FREE PLOTS.
READY
>%ASE,A PLOTS.
READY
>%USE 4.,PLOTS. FORTRAN UNIT 4
READY
>%ASE,TJ TAPE.,8C,X11837
WAITING ON FACILITY
READY
>%REIND TAPE.
PURPLE 27R30 E33 5L73R1 06/17/80 15:05:15
>%COPY TAPE.,DATA.
3 BLOCKS COPIED.
EOF ENCOUNTERED ON INPUT TAPE
>%REIND TAPE.
>%FREE TAPE. DO NOT TIE UP TAPE DRIVES LONGER THAN NECESSARY
READY
>%NOT ALT.TFEAR.
*GCS-SIGN-ON TO F6 CONFIRMED*

```

ORIGINAL PAGE IS  
OF POOR QUALITY

Figure A-2. Computer Control